

Element B | Shell

Exterior Enclosure

B2030 Exterior Doors

PART 1 - GENERAL

1.01 OVERVIEW

- A. Includes exterior entrances, personnel, and overhead doors.

PART 2 - DESIGN CRITERIA

2.01 GENERAL

- A. Entrances shall be aluminum and glass or stainless and glass. Design building entrances in a vestibule configuration with motor operated sliding doors in high traffic locations and patient care facilities when applicable.
- B. Solid exterior doors shall be galvanized, primed and painted full flush hollow metal doors with closed top rail in welded hollow metal, galvanized frames. Doors shall meet U-value requirements of ANSI/ASHRAE/IESNA 90.1.
- C. Overhead doors shall be painted metal with motor operators.

Element B | Shell

Exterior Enclosure

B2030 Exterior Doors

PART 3 - DOCUMENT REVISION HISTORY

Issue	Date	Revision Description	Revised By
	20190301	Original Issuance	
Rev. 1			
Rev. 2			
Rev. 3			
Rev. 4			
Rev. 5			

END OF ELEMENT B2030